

CERTIFICATE OF COMPLIANCE

Certificate Number 20181030-EX27914
Report Reference EX27914-20181024
Issue Date 2018-OCTOBER-30

Issued to: I MIST HOLDINGS LIMITED
293 National Avenue,
The Ideal Business Park,
Hull, HU5 4JB UNITED KINGDOM

This is to certify that representative samples of WATER-MIST STRAINERS
USL, CNL Water-mist strainer, Y Type Model- STS 12

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: NFPA 750-Standard on Water Mist Fire Protection Systems, UL Subject 321-Pipeline Strainers

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

